

**RICK TELEGAN**

---

**From:** Moua, Bounma <  
**Sent:** Thursday, August 24, 2017 2:57 PM  
**To:** Rick Telegan  
**Cc:** Moua, Bounma  
**Subject:** RE: PG & E easement

Rick,  
I hope all is well with you. I apologize for the late response, I've been extremely busy since my return.

I was able to determine that PG&E would not allow a swale to be created beneath the transmission tower lines. The response was that the proposed design would be unacceptable because it would impair our right to maintain our facilities as well it disturbing the grounds beneath the facilities.

I understand this isn't response you had hope for, but if you have other proposal that you would like review, please let me know.

Thank you.

**Bounma Moua** | Land Agent  
**Pacific Gas and Electric Company** | Land Management  
559.263.5688 office | 821.5688 internal |

---

**From:** Rick Telegan  
**Sent:** Friday, July 21, 2017 10:32 AM  
**To:** Moua, Bounma  
**Cc:**  
**Subject:** Fwd: PG & E easement

\*\*\*\*\***CAUTION:** This email was sent from an EXTERNAL source. Think before clicking links or opening attachments.\*\*\*\*\*

Bounma....This email is in response to your request for an exhibit depicting our proposed swale necessary for us to satisfy our storm water detention requirements of the city. Call me, or Jim (@GVE) if you have any questions. Thx

---

**From:** Jim Xu  
**To:** Rick Telegan  
**Sent:** 7/27/2017 10:08:01 A.M. Pacific Daylight Time  
**Subj:** PG & E easement

Hi Rick,

Attached is sketch for proposed basin within PG & E easement.

Please let me know if you have any questions.